

ARTICLE

Partition Optimization of Hydroelectricity Power System and Appropriate Option of Renewable Energy Source in Terms of Probabilistic Multi-Objective Optimization

Maosheng Zheng^{1*}, Jie Yu²

¹School of Chemical Engineering, Northwest University, Xi'an 710127, China

²School of Life Sciences, Northwest University, Xi'an 710069, China

ABSTRACT

The partition optimization and option of renewable energy source for specific place are basic problems which include multiple objectives, such as cost, benefit, and adjustable performance, etc. Particularly, partition optimization is a specific optimal design under the constraint condition of the summation of the proportion of each component being 100%, i.e., a “mixture design” problem in principle. In this paper, the combination of probabilistic multi-objective optimization (PMOO) with uniform design for mixture (UDM) is employed to solve the problems of partition optimization and the option of renewable energy source for specific place. In the study, PMOO is used to converse the multi-objective optimization problem (MOO) into a mono-objective one, and UDM with discretization treatment is used to provide a greatly simplified assessment with a set of homogeneous sampling points in the optimization design with the constraint condition of the summation of total partition ratios being 100% specifically. In the optimization of partition ratios of a hydroelectricity power system, the total estimated expenditure is minimized, and the annual average power generation of three hydropower stations is maximized in the system. It gives the rounding-off optimum partitions of the three hydropower stations as 66 kW, 55 kW and 109 kW under the condition of a total installed capacity of 230 kW, respectively; the total cost and annual power generation are 4.3251 billion yuan and 127.7356 billion degrees correspondingly. Subsequently, the study on the selection of renewable energy source in specific place in India results in solar energy as the appropriate option.

Keywords: Partition; PMOO; Preferable Probability; Uniform Design for Mixture; Discretization

***CORRESPONDING AUTHOR:**

Maosheng Zheng, School of Chemical Engineering, Northwest University, Xi'an 710127, China; Email: 1914994032@qq.com

ARTICLE INFO

Received: 10 December 2024 | Revised: 1 January 2025 | Accepted: 5 January 2025 | Published Online: 11 January 2025

DOI: <https://doi.org/10.54963/cet.v1i1.1476>

CITATION

Zheng, M., Yu, J., 2025. Partition Optimization of Hydroelectricity Power System and Appropriate Option of Renewable Energy Source in Terms of Probabilistic Multi-Objective Optimization. *Clean Energy Technologies*. 1(1): 1–11. DOI: <https://doi.org/10.54963/cet.v1i1.1476>

COPYRIGHT

Copyright © 2025 by the author(s). Published by UK Scientific Publishing Limited. This is an open access article under the Creative Commons Attribution 4.0 International (CC BY 4.0) License (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

Distribution of installed capacity of hydroelectricity power stations is a typical optimization problem with multiple objectives (MOO) in the optimal option. In a hydropower station system, not only is the investment of a system concerned, but also the power generation, the adjustable performance (power generation quality), the comprehensive utilization benefit of hydropower resources in a system, etc., are all involved, and the benefits of individual power stations need to be considered as well^[1]. Therefore, the proper distribution of installed capacity is undoubtedly a multi-objective optimization problem.

On the other hand, the increase in populations and industrialization aggravates the energy consuming in the world; it experiences a tremendous rise in energy demand due to growing economies and modernization^[2]. As a result, some countries or regions are even faced with an energy crisis due to the contradiction between their demands and the supply of fossil energy resources^[3,4]. Therefore, the exploration of renewable energy (RE) has been increasing rapidly worldwide. Globally, there are various renewable energy resources available in different regions; therefore, an appropriate selection and utilization of these renewable energy sources are quite important for an explorer to achieve efficient and reasonable application. Unavoidably, the appropriate option of these renewable energy sources involves the comprehensive assessment and comparison of each RE resource in financial, technical, infrastructure management and maintenance, land requirements, and socio-economic aspects, etc.^[4]. Therefore, it is a simultaneous optimization problem with multiple objectives. These multiple objectives also involve uncertainty and conflicting criteria. Inevitably, researchers have to employ proper approaches to multi-objective optimization (MOO) to address the matter.

Commonly, in traditional approaches (in fact, algorithms solely) of MOO, it is difficult to find an optimal solution for the MOO problem; it could only yield a so-called non-inferior solution or satisfactory solution instead of an actual optimal solution as a whole, such as those of the Pareto front, etc.^[5,6].

Although there have been many algorithms to find satisfactory solutions, they are all problematic. Roughly, the algorithms can be divided into two categories. One is hierarchical analysis based on vector optimization theory and utility theory. The non-inferior solution set is obtained in a certain way first, and then the utility function is constructed or the scheme is optimized by weighted average. The other algorithm is a multi-stage, multi-level and even multi-objective fuzzy optimization approach. It selects the satisfactory solution from the non-inferior solution set according to the minimum Euclidean weighted distance. Both of the above algorithms are based on the comparison and screening of a limited number of schemes in the non-inferior solution set of intermediate problems, and the premise is to form a non-inferior solution set containing a limited number of schemes first. In addition, it contains unknown parameters, such as weight factors, normalized factors, "virtual solution", etc.

A more serious problem is that it adopts the operation mode of "additive algorithm", which actually has the meaning of "union" from the perspective of set theory. However, the essence of MOO is to conduct the optimization of multiple objectives at the same time, which should belong to the mode of "intersection" from the perspective of set theory. Therefore, the actual case is that the past algorithms could not reflect the scientific connotation of the simultaneity of MOO^[5-8]. A Pareto solution, also known as a non-inferior solution or an efficient solution, is a concept of a solution in multi-objective optimization. Pareto optimality was proposed by the Italian economist Pareto in 1879 and thereafter. Pareto solutions are generally not unique. The key to solving such multi-objective optimization problems lies in selecting the most satisfactory result according to some rational criterion. Subsequently, numerous multi-objective optimization algorithms have been developed to obtain the Pareto front instead of the actual optimal solution^[9-18]. What kind of results can these algorithms provide? The analysis shows that the results they can provide include: 1. Pareto optimal set: a collection of non-dominated solutions, each representing a trade-off; 2. Pareto front: a visualization of these solutions' performance in the objective space, forming a curve (or

surface). For example: (1) In a portfolio optimization, the Pareto front may illustrate the trade-off between “risk vs. return”; (2) In engineering design, it may show the trade-off between “strength vs. weight”. The practical significance of these algorithms is that they offer “all possible trade-offs” for decision-makers to choose from actual needs instead of a “single correct answer”. Although these methods have been applied in many fields to varying degrees, they have inherent defects.

This situation indicates the necessity of an appropriate approach that could reveal the simultaneity of optimization with multiple objectives actually. Improper selection and utilization of approaches for MOO often result in invaluable or misleading consequences.

Recently, probabilistic multi-objective optimization (PMOO) was proposed to deal with the optimization problem with multiple objectives concurrently in a system^[5,6], which aims to reveal the intrinsic simultaneity of the multiple objectives in optimization within the system. Besides, the optimization of a system being the whole / integral optimization of the system is taken into consideration as the fundamental view.

The fundamental thought of PMOO is based on the following considerations^[5,6]. Multi-objective optimization refers to the situation where the object (system) under study contains multiple objectives that cannot be separated and must be optimized simultaneously. This is its completeness. For example, a material used in aircraft manufacturing needs to be strong and durable, as well as lightweight and resistant to environments. Many material properties (objectives) are involved, such as strength, toughness, lightweight, and environmental resistance, which are inseparable indicators within the material and cannot be isolated. In other words, certain constraints must be considered to achieve high strength and lightweight simultaneously in a material, because high strength and lightweight (low density) are conflicting indicators which coexist within the material; they are mutually restricting each other and being inseparable.

Indeed, in multi-objective optimization problems, these properties need to be optimized simultaneously to enable the system as a whole to function/work properly! These properties are interrelated and constrained,

so it is impossible to adjust one without affecting the others! The system’s environmental adaptability is also a crucial performance metric for its reliability and success. Therefore, from a systems theory perspective, a multi-objective optimization problem is essentially an optimization of the entire system. Each objective is an organic part of the system.

Addressing the issue of optimizing multiple objectives simultaneously involves treating the system as a whole for optimization, i.e., putting the entire system in the best possible state, with its various parts working together and uniting under the banner of “overall optimization”.

Only when all parts (objectives) of the system are coordinated can the system reach an integrated optimization and realize the overall function of the system. Therefore, according to systems theory, the optimization of the system should be: (1) overall optimization; (2) hierarchical optimization at each stage; (3) collaboration among all parties.

Additionally, from the perspective of systems theory, “the whole system does not equal the simple sum of its components” but rather “the whole is greater than the sum of its parts”.

However, previous (so-called) multi-objective optimization algorithms, such as linear weighting or “ ϵ -constraint”, which treat “weighted summation” or “selecting one of the k objectives” as the optimization goal while converting the remaining $(k-1)$ objectives into constraints, they all diverge from the essence of “simultaneous optimization of multiple objectives” and deviate from the intrinsic nature of “overall system optimization”. Moreover, the selection of weight factors and normalization factors for each attribute in the “linear weighting” method also poses issues.

Given that the essence of “multi-objective optimization” means “simultaneous optimization of multiple objectives”, it is fundamentally “overall system optimization”. Therefore, it is necessary to find the “intersection” between objectives, making them coordinate with each other to achieve optimal functionality of the entire system.

The concept of “intersection” comes from set theory, involving two sets A and B , where the intersection

is the set consisting of all elements that belong to both A and B, denoted as $A \cdot B$ or $A \cap B$. In probability theory, the probability $P(A \cap B)$ of two independent events occurring simultaneously equals $P(A) \cdot P(B)$, i.e., $P(A \cap B) = P(A) \cdot P(B)$, known as the joint probability of the two independent events A and B. Additionally, from the perspective of systems theory, systems can take various forms, and each component within a system can also have diverse forms. Materials in multi-objective material selection have the form of an entity system, while their properties such as elastic modulus, tensile strength, and elongation more closely resemble conceptual systems. For problems involving simultaneous optimization of multiple objectives, Derringer et al. and Jorge et al. transform each objective into its satisfaction value and then combine all satisfaction values using their geometric mean to obtain a total satisfaction value representing the overall evaluation of this combination^[19,20]. However, from a probabilistic standpoint, this patchwork approach fundamentally does not align with the essence of optimizing multiple objectives simultaneously^[5,6]. Therefore, it is necessary to construct a methodological framework for simultaneous optimization of multiple objectives from the perspectives of systems theory and probability theory rationally, which leads to the emergence of probability-based multi-objective optimization methods.

In probability theory, the “product” of the probabilities of two individual events reflects the “simultaneous occurrence” of these events, and the “intersection” of two individual subsets reveals the “simultaneous occurrence” in both subsets in set theory. Therefore, if the probability theory method is adopted to conduct the issue of simultaneous optimization of multiple objectives, the subsequent problem is to quantify the attribute response of all objectives (attributes) of alternative candidates. So, in PMOO, the preference degree of an attribute in the optimization was reflected by a novel idea called “preferable probability”^[2,3]. Moreover, all objectives (attributes) of candidate schemes in the optimization are grouped into either beneficial kinds of attributes or unbeneficial kinds of attributes preliminarily. Furthermore, a quantitative evaluation of each attribute to its corresponding candidate scheme is per-

formed by a new index called partial preferable probability initially^[5,6].

Thus, the product of all its partial preferable probabilities of a candidate scheme leads to a total preferable probability, which is the unique index of this candidate scheme. Finally, the total preferable probability of each scheme is its uniquely decisive representative to compete in the optimization process undoubtedly^[5,6].

Obviously, PMOO is promised to perform the concurrent optimization problem of multiple objectives as a whole, so as to get effective and valuable consequences. The assessments of PMOO are introduced as follows briefly.

For beneficial kinds of objectives^[5,6], the partial preferable probability P_{ij} is evaluated with Equation (1),

$$\begin{aligned} P_{ij} &= \gamma_j \chi_{ij} \\ \gamma_j &= 1 / (n \overline{\chi_j}) \\ i &= 1, 2, \dots, n \\ j &= 1, 2, \dots, m \end{aligned} \quad (1)$$

As to unbeneficial types of objectives^[5,6], it has,

$$\begin{aligned} P_{ij} &= \eta_j (\chi_{j\min} + \chi_{j\max} - \chi_{ij}) \\ \eta_j &= 1 / [n (\chi_{j\min} + \chi_{j\max} - \overline{\chi_j})] \end{aligned} \quad (2)$$

Finally, the total preferable probability P_i of the i -th alternative scheme is^[5,6],

$$P_i = P_{i1} \cdot P_{i2} \cdot P_{i3} \cdots P_{im} = \prod_{j=1}^m P_{ij} \quad (3)$$

In Equation (1) through Equation (3), χ_{ij} is the performance utility index of the j -th objective of the i -th candidate; n is the total number of alternatives; m reflects the total number of objective; $\overline{\chi_j}$ indicates the mean value of the utility index of the j -th objective within the involved candidates; $\chi_{j\min}$ and $\chi_{j\max}$ are the minimum and maximum values of the performance utility index involved in j -th objectives, respectively; γ_j and η_j indicate the normalization factors of the j -th utility index χ_{ij} in cases of beneficial kinds and unbeneficial kinds, respectively^[2,3]. In addition, the probabilistic robust design of the production process and product

was developed on the basis of the viewpoint of systems theory^[21,22].

In fact, there exist distinct differences between PMOO and traditional approaches for MOO problems. The main differences are reflected in the fact that PMOO contains both the viewpoint of systems theory and mathematical algorithms. From the point of view of systems theory, “the optimum point of the optimization problem of multiple objectives” is the “optimal point of the system”, and the latter can be obtained by using probability theory. However, traditional approaches for MOO problems lack any viewpoint for the optimum point but only algorithms, which lead to the consequence that the optimum point of the “optimization problem with multiple objectives” is not defined.

Besides, partition optimization is a specific optimal design problem, which has a typical characteristic of the ratios of input partition variables usually being restrained by common constraint conditions, $x_{i0} \geq 0$, $i = 1, 2, \dots, s$, and $\sum_{i=1}^s x_{i0} = 1$ ^[23], in which x_{i0} reflects the i -th input partition variable and s indicates the number of input partition variables. Such kind of problem with the above constraints for input variables is called “mixture design” in the chemical industry, material manufacturing industry and design of food formulas^[23]. Therefore, the uniform design for the mixture problem (UDM) proposed by Fang et al. could be employed to deal with the problem of partition optimization^[23]; it provides a set of homogeneous sampling points in the mixture design under the above constraint conditions. In fact, the uniformly distributed sampling points can be used to conduct the subsequent data processing in the optimization process by means of discretization especially.

In this paper, the combination of PMOO with UDM is used to solve the problem of partition optimization of hydroelectricity power system in order to get an appropriate option first. The total calculation expenditure of a hydroelectricity power system and its annual average power generation are taken as the dual objectives to get global optimization with proper partition distributions of installed capacity of three hydropower stations. Subsequently, appropriate selection of renewable energy source for specific place is conducted in terms of probabilistic multi-objective optimization.

2. Materials and Methods

2.1. Uniform Design for Mixture Design with Three Input Variables

Uniform Design for Mixture Design (UDM) was proposed by Fang et al.^[21], it provides a homogeneous sampling points in mixture design under constraint conditions of $x_{i0} \geq 0$, $i = 1, 2, \dots, s$, and $\sum_{i=1}^s x_{i0} = 1$ ^[23]. In detail, Fang et al. established a procedure to deduce a specific table $UM_r(r^s)$ to spread the sampling points in the input variable – space accordingly^[23].

As to a UDM with three input variable ratios ($s = 3$), i.e., x_{10} , x_{20} , x_{30} , the number of sampling points $r = 19$ can be employed in our treatment^[5]; the corresponding uniform design table $U^*_r(r^t)$ or $U_r(r^t)$ and its usage table can be chosen accordingly^[23,24]. Under such conditions, the number of columns of the usage table could be set as $s - 1$.

While, the elements in the original uniform design table $U^*_r(r^t)$ or $U_r(r^t)$ are marked by $\{q_{ik}\}$ ^[23,24]. Accordingly, the following procedures are formulated^[23,24].

(I) Construction of a novel element c_{ki}

As to each i , a novel element c_{ki} is built by using the following formula^[23,24],

$$c_{ki} = (2q_{ki} - 1)/(2r) \quad (4)$$

(II) Construction of uniform sampling points for the mixtures, y_{ki0}

Following formula is employed to complete the construction^[23,24],

$$x_{ki0} = \left(1 - c_{ki}^{\frac{1}{s-j}}\right) \prod_{j=1}^{i-1} c_{kj}^{\frac{1}{s-j}}, i = 1, 2, \dots, (s-1) \quad (5)$$

$$x_{ks0} = \prod_{j=1}^{s-1} c_{kj}^{\frac{1}{s-j}}, k = 1, 2, \dots, r \quad (6)$$

Thus, $\{x_{ki0}\}$ is deduced, which could be employed to build the corresponding uniform design table $UM_r(r^s)$ of the mixture under the conditions of specific n and s .

Based on the uniform design table $U^*_{19}(19^7)$ of Fang et al.^[23,24], a uniform test table $UM_{19}(19^3)$ with mixtures can be built, which is shown in **Table 1**. Besides,

here we have $s = 3$ for three input variables, $r = 19$ for the number of sampling points, so it derives the following expressions from the above rules,

$$\begin{aligned} x_{k10} &= 1 - c_{k1}^{0.5} \\ x_{k20} &= c_{k1}^{0.5} \cdot (1 - c_{k2}) \\ x_{k30} &= c_{k1}^{0.5} \cdot c_{k2} \end{aligned} \quad (7)$$

Table 1. Uniform test table $UM_{19}(19^3)$ with mixtures based on uniform design table $U_{19}^*(19^7)$.

No.	q_{10}	q_{20}	c_1	c_2	x_{10}	x_{20}	x_{30}
1	1	9	0.0263	0.4474	0.8378	0.0896	0.0726
2	2	18	0.0789	0.9211	0.7190	0.0222	0.2588
3	3	7	0.1316	0.3421	0.6373	0.2386	0.1241
4	4	16	0.1842	0.8158	0.5708	0.0791	0.3501
5	5	5	0.2368	0.2368	0.5133	0.3714	0.1153
6	6	14	0.2895	0.7105	0.4620	0.1557	0.3823
7	7	3	0.3421	0.1316	0.4151	0.5079	0.0770
8	8	12	0.3947	0.6053	0.3717	0.2480	0.3803
9	9	1	0.4474	0.0263	0.3311	0.6513	0.0176
10	10	10	0.5000	0.5000	0.2929	0.3536	0.3536
11	11	19	0.5526	0.9737	0.2566	0.0196	0.7238
12	12	8	0.6053	0.3947	0.2220	0.4709	0.3071
13	13	17	0.6579	0.8684	0.1889	0.1067	0.7044
14	14	6	0.7105	0.2895	0.1571	0.5989	0.2440
15	15	15	0.7636	0.7632	0.1264	0.2069	0.6667
16	16	4	0.8158	0.1842	0.0968	0.7368	0.1664
17	17	13	0.8684	0.6579	0.0681	0.3188	0.6131
18	18	2	0.9211	0.0789	0.0403	0.8839	0.0758
19	19	11	0.9737	0.5526	0.0132	0.4414	0.5453

2.2. Combination of PMOO with UDM

In light of uniform design for mixture design (UDM), the assessments of continuous functions of objectives within their valid domain can be replaced by the evaluations of the limited number of values of the corresponding objectives at the typical sampling points, which greatly simplifies assessments.

In order to perform assessments of PMOO, the values of objective functions at every sampling point can be conducted first accordingly. Subsequently, the corresponding result of partial preferable probability for each objective at every sampling point, and the total preferable probability at every sampling point can be conducted.

All these procedures form the Combination of PMOO with UDM, which makes it possible for PMOO evaluations at the typical sampling points of UDM.

The sampling points provided in **Table 1** are for the case of partition optimization with three input partition variables only, while for other numbers of input variables it can be conducted according to Fang et al. [23,24]. Two application examples are provided in this section.

3. Results

3.1. Application of Combination of PMOO with UDM in Partition Optimization of Hydroelectricity Power System

In the optimization problem of distributions of installed capacity of the hydropower system, it often involves the total investment, the system power generation, power generation quality (adjustable performance), and the comprehensive utilization benefit of hydropower resources, etc. In this section, the allocation of installed capacity of hydropower stations in a system is optimized with the total expenditure and the average power generation for many years as dual objectives of the system.

Li, Shang and Huang raised a partition problem of three hydropower stations in a system power generation [1], which involves minimizing total estimated expenditure C , of the system and maximizing the annual average power generation E in China. **Table 2** shows the relationship among the installed capacity y of three hydropower stations, the estimated expenditure C and annual average power generation E in the power system from Li, Shang and Huang [1].

Table 2. Data of relationship among the installed capacity of 3 hydropower stations, estimated expenditure and average annual power generation [1].

No.	Installed Capacity y (kW)	Cost C (billion yuan)	Annual Power Generation E (billion degree)
	y_1	C_1	E_1
Station 1	60	1.5780	32.0
	70	1.5890	36.5
	80	1.6050	41.1
	90	1.6117	43.6
	100	1.6335	45.5

No.	Installed Capacity y (kW)	Cost C (billion yuan)	Annual Power Generation E (billion degree)
Station 2	y_2	C_2	E_2
	40	1.5200	27.0
	50	1.5460	32.6
	60	1.5680	37.7
	70	1.5910	42.1
	80	1.6200	45.4
Station 3	y_3	C_3	E_3
	80	1.5800	41.9
	90	1.6120	48.5
	100	1.6520	53.0
	110	1.6900	57.09
	120	1.7280	61.0

The restraint condition of the hydropower system is that the total installed capacity of the hydropower stations is 230 kW in the system^[1], i.e., $y_1 + y_2 + y_3 = 230$ kW, and the ranges of installed capacity of each power station were $y_1 \in [60, 100]$ in kW, $y_2 \in [40, 80]$ in kW and $y_3 \in [80, 120]$ in kW, respectively^[1]; here y_i indicates the installed capacity of the i -th each power station, $i = 1, 2, 3$.

Furthermore, it is stated that this optimization problem is to take the minimizing total estimated expenditure C of the system and maximizing the annual average power generation E as dual objectives under the restraint conditions of total installed capacity of the three hydropower stations in the system being 230 kW and the corresponding ranges of installed capacity of each power station.

From the data in **Table 2**, the following regressed relationships can be obtained,

$$C_1 = 9 \times 10^{-6} y_1^2 - 7 \times 10^{-5} y_1 + 1.551, R^2 = 0.9827 \quad (8)$$

$$E_1 = -0.0052 y_1^2 + 1.1753 y_1 - 19.869, R^2 = 0.998 \quad (9)$$

$$C_2 = 5 \times 10^{-6} y_2^2 + 0.0019 y_2 + 1.439, R^2 = 0.9983 \quad (10)$$

$$E_2 = -0.0038 y_2^2 + 0.9173 y_2 - 3.691, R^2 = 0.9998 \quad (11)$$

$$C_3 = 7 \times 10^{-6} y_3^2 + 0.0023 y_3 + 1.348, R^2 = 0.9994 \quad (12)$$

$$E_3 = -0.0041 y_3^2 + 1.295 y_3 - 35.022, R^2 = 0.998 \quad (13)$$

The optimum problem can be expressed as an optimization issue with dual objectives in the following

formulae,

$$\min C = C_1 + C_2 + C_3 \quad (14)$$

$$\max E = E_1 + E_2 + E_3 \quad (15)$$

$$\text{s.t.: } y_1 + y_2 + y_3 = 230 \text{ kW} \quad (16)$$

$$\text{s.t.: } 60 \text{ kW} \leq y_1 \leq 100 \text{ kW}, 40 \text{ kW} \leq y_2 \leq 80 \text{ kW}, 80 \text{ kW} \leq y_3 \leq 120 \text{ kW} \quad (17)$$

Obviously, this problem is an optimization issue of dual objectives with mixture design^[5,23]. Since the objective functions C and E are continuous functions in the independent partition variable space consisting of y_1, y_2 and y_3 now, an effective treatment is to deal with it by using a discretizing algorithm in the independent variable space with a certain number of sampling points^[5,23].

Subsequently, 19 uniformly distributed sampling points are necessary to be employed to conduct this mixture design issue in 3-D space fundamentally in light of the study on the number of sampling points^[5,21,23], which is shown in **Table 3**.

Table 3. 19 uniformly distributed sampling points for this mixture design issue.

No.	Position of Sampling Point		
	y_1 (kW)	y_2 (kW)	y_3 (kW)
1	97.76162	45.56711	86.67120
2	92.79553	42.74579	94.45861
3	89.37638	51.79781	88.82575
4	86.59717	45.12443	98.27834
5	84.19402	57.34951	88.45641
6	82.04610	48.33113	99.62271
7	80.08608	63.05918	86.85468
8	78.27187	52.18931	99.53876
9	76.57509	69.05245	84.37240
10	74.97551	56.60313	98.42130
11	73.45814	42.63626	113.90550
12	72.01145	61.50979	96.47870
13	70.62641	46.28120	113.09230
14	69.29575	66.86399	93.84019
15	68.01353	50.47046	111.51590
16	66.77481	72.63104	90.59409
17	65.57544	55.15001	109.27450
18	64.41191	78.78325	86.80478
19	63.28116	60.27850	106.44030

Moreover, the values of functions C and E at these

19 sampling points are evaluated, which are shown in **Table 4**.

Table 4. Values of functions C and E at the 19 sampling points.

No.	Value of Function	
	C (billion yuan)	E (billion degree)
1	4.367772	121.9677
2	4.344959	123.7122
3	4.366799	124.9223
4	4.337318	125.5252
5	4.373035	126.0890
6	4.337090	126.6202
7	4.383253	126.4722
8	4.341254	127.3559
9	4.396629	126.2229
10	4.348747	127.7925
11	4.300760	126.2080
12	4.359072	127.9096
13	4.306410	126.8172
14	4.371971	127.6549
15	4.314466	127.3428
16	4.387316	126.9598
17	4.324759	127.7117
18	4.405048	125.7471
19	4.337202	127.8438

The assessments of partial preferable probabilities of functions C and E , and the total preferable probabilities at 19 sampling points, as well as ranking, are shown in **Table 5**. In the assessments, the regressed relationships are employed.

Table 5 shows that the highest total preferable probability appears at the 17th sampling point, which can be selected as the optimized status. The corresponding partition variables y_1^* , y_2^* and y_3^* , are 65.57544 kW, 55.15001 kW and 109.27450 kW, respectively. The total cost C^* and annual power generation E^* are 4.324759 billion yuan and 127.7117 billion degrees correspondingly. The rounding-off values are, $y_1' = 66$ kW, $y_2' = 55$ kW and $y_3' = 109$ kW, respectively; the corresponding total cost C' and annual power generation E' , are 4.3251 billion yuan and 127.7356 billion degrees individually.

These results are superior to those given by Li, Shang and Huang with their fuzzy multi-objective optimization approach ^[1], i.e., y_1'' , y_2'' and y_3'' , are 80 kW, 60 kW and 90 kW, respectively. Their total cost C'' and annual power generation E'' , are 4.785 billion yuan and

127.3 billion degrees correspondingly. Obviously, the total cost C'' of Li, Shang and Huang is greater than C' of our approach, and their annual power generation E'' is lower than ours.

Table 5. Assessment of partial preferable probabilities of functions C and E and total preferable probabilities at the 19 sampling points, as well as ranking.

No.	Partial Preferable Probability		Total Preferable Probability	Rank
	P_C	P_E	$P_t \times 10^3$	
1	0.0525	0.0508	2.6645	19
2	0.0527	0.0515	2.7169	18
3	0.0525	0.0520	2.7297	16
4	0.0528	0.0523	2.7616	11
5	0.0524	0.0525	2.7512	14
6	0.0528	0.0527	2.7859	10
7	0.0523	0.0527	2.7530	13
8	0.0528	0.0530	2.7994	8
9	0.0521	0.0526	2.7390	15
10	0.0527	0.0532	2.8041	5
11	0.0533	0.0526	2.8000	6
12	0.0526	0.0533	2.8000	7
13	0.0532	0.0528	2.8099	4
14	0.0524	0.0532	2.7860	9
15	0.0531	0.0530	2.8164	2
16	0.0522	0.0529	2.7610	12
17	0.0530	0.0532	2.8179	1
18	0.0520	0.0524	2.7233	17
19	0.0528	0.0532	2.8127	3

3.2. Application of Probability-Based Multi-Objectives Optimization in Appropriate Option of Renewable Energy Source

In this section, the example for optimal renewable energy source of Husain et al. is reanalyzed with PMOO. Husain et al. once raised the optimal renewable energy source in India ^[4]. It involves the comparative option of hydropower, solar energy, wind energy and biomass energy, while the assessed criteria include financial response, technical maturity and efficiency, environmental effect, and social benefit, etc. Furthermore, they gathered data for each kind of RE resource ^[4], which is cited in **Table 6** here for our restudy. Besides, the types of the objectives (O_i through O_{10}) are indicated clearly.

Table 6. Gathered data for each kind of RE resource.

Criterion	Total Installed Cost, \$ kW ⁻¹ , O ₁	O&M Cost, \$ kW ⁻¹ y ⁻¹ , O ₂	LCOE, \$ kWh ⁻¹ , O ₃	Efficiency, %, O ₄	Capacity Factor, %, O ₅
Type of Criterion	Non-Beneficial	Non-Beneficial	Non-Beneficial	Beneficial	Beneficial
Solar	596	9.000	0.038	22.00	19
Wind	1038	28.000	0.040	35.00	33
Hydro	1817	45.425	0.065	76.61	57
Biomass	1154	46.160	0.057	84.33	68

Continue

Criterion	GHG Emission, g CO ₂ kWh ⁻¹ , O ₆	Land Requirement, m ² kW ⁻¹ , O ₇	Job Creation, Job-years GWh ⁻¹ , O ₈	Technical Maturity, 1-5 Score, O ₉	Social Acceptance, 1-5 Score, O ₁₀
Type of Criterion	Non-Beneficial	Non-Beneficial	Beneficial	Beneficial	Beneficial
Solar	48	12	0.870	4	4.58
Wind	11	250	0.170	4	4.17
Hydro	24	500	0.270	5	3.56
Biomass	230	13	0.210	3	4.00

Distinctly, the assessment of this issue can be done easily by using the approach of probability-based multi-objectives optimization (PMOO). The evaluated results with rank are presented in **Table 7**. The ranking is conducted with the total preferable probability of each alternative candidate from higher to lower. It reveals that solar energy in the concerned area is the best selection, which has the highest total preferable probability in the optimal comparison. Undoubtedly, as to the optimal assessment of other places, their appropriate criteria (objectives) and their roles might be of course concerned. Other applications of PMOO show bright prospects as well, such as utilizations in portfolio investment, shortest path problems with multiple objectives, and options of thermofluids, etc. ^[25-29].

Table 7. Evaluated results of this issue.

Type of RE	Partial Preferable Probability					
	P ₀₁	P ₀₂	P ₀₃	P ₀₄	P ₀₅	P ₀₆
Solar	0.3600	0.5014	0.3066	0.1009	0.1073	0.2965
Wind	0.2724	0.2950	0.2972	0.1606	0.1864	0.3533
Hydro	0.1181	0.1058	0.1792	0.3515	0.3220	0.3333
Biomass	0.2495	0.0978	0.2170	0.3869	0.3842	0.0169

Continue

Type of RE	Partial Preferable Probability					Rank
	P ₀₇	P ₀₈	P ₀₉	P ₀₁₀	P _i '10 ⁶	
Solar	0.3928	0.5724	0.2500	0.2808	2.8063	1
Wind	0.2058	0.1118	0.2500	0.2557	0.3718	2
Hydro	0.0094	0.1776	0.3125	0.2183	0.0096	4
Biomass	0.3920	0.1382	0.1875	0.2452	0.0331	3

4. Discussion

Since the total installed capacity of the hydropower stations in a power system in general is limited and fixed, i.e., the ratio of input partition variable is usually restrained by the common constraint condition of the summation of the proportion of each component being 1 ($\sum_{i=0}^s x_{i0} = 1, x_{i0} \geq 0, i = 1, 2, \dots, s$), which is a typical "mixture design" problem, therefore the combination of probabilistic multi-objective optimization (PMOO) with uniform design for mixture (UDM) is proper to be used to solve problems of such partition optimization undoubtedly. The consequences of the application example confirm the validity of the approach.

5. Conclusions

The above study indicates that the combination of probabilistic multi-objective optimization with mixture design can be successfully used to conduct partition optimization problems; the probabilistic multi-objective optimization is used to convert optimization problems with multiple objectives into a mono-objective one, and the discretization is conducted by using uniform design with mixture to provide a set of homogeneous sampling points in optimization design.

The evaluated results for the appropriate option of renewable energy resources reveal that solar energy in the specific area is the best selection. The optimal as-

assessment and selection of other places might concern their actual data of criteria exactly. More exploration of probabilistic multi-objective optimization in broad fields is still open and in need.

Author Contributions

Conceptualization, M.Z. and J.Y.; methodology, M.Z.; validation, J.Y.; formal analysis, M.Z.; writing—original draft preparation, J.Y.; writing—review and editing, M.Z. All authors have read and agreed to the published version of the manuscript.

Funding

This work received no external funding.

Institutional Review Board Statement

Not applicable.

Informed Consent Statement

Not applicable.

Data Availability Statement

Not applicable.

Acknowledgments

Not applicable.

Conflicts of Interest

The authors declare no conflict of interest.

References

- [1] Li, H., Shang, C., Huang, Q., 2000. Multi-objective fuzzy optimization theory and application in hydroelectric power system. *System Engineering*. 18(1), 60–63.
- [2] Stein, E.W., 2013. A comprehensive multi-criteria model to rank electric energy production technologies. *Renewable and Sustainable Energy Reviews*. 2, 640–654.
- [3] Siksneelyte, I., Zavadskas, E.K., Streimikiene, D., et al., 2018. An overview of multi-criteria decision-making methods in dealing with sustainable energy development issues. *Energies*. 11(10), 2754. DOI: <https://doi.org/10.3390/en1102754>
- [4] Husain, A.M., Hasan, M.M., Khan, Z.A., et al., 2024. A robust decision-making approach for the selection of an optimal renewable energy source in India. *Energy Conversion and Management*. 301, 117989
- [5] Zheng, M., Yu, J., Teng, H., et al., 2023. Probability-Based Multi-Objective Optimization for Material Selection, 2nd ed. Springer: Singapore. DOI: <https://doi.org/10.1007/978-981-19-3351-6>
- [6] Zheng, M., Wang, Y., Teng, H., 2021. A new “intersection” method for multi-objective optimization in material selection. *Technicki Glasnik*. 15(4), 562–568. DOI: <https://doi.org/10.31803/tg-20210901142449>
- [7] Truong, N.X., Ašonja, A., Trung, D.D., 2023. Enhancing handheld polishing machine selection: An integrated approach of marcos methods and weight determination techniques. *Applied Engineering Letters*. 8(3), 131–138. DOI: <https://doi.org/10.18485/aeletters.2023.8.3.5>
- [8] Mohiuddin, M.V., Krishnaiah, A., Hussainy, S.F., et al., 2016. Influence of process parameters on quality of Al7SiMg alloy casting using statistical techniques. *Materials Today: Proceedings*. 3(10), 3726–3733. DOI: <https://doi.org/10.1016/j.matpr.2016.11.020>
- [9] Zhong, C., Li, G., Meng, Z., et al., 2025. Starfish Optimization Algorithm (SFOA): A bio-inspired metaheuristic algorithm for global optimization compared with 100 optimizers. *Neural Computing and Applications*. 34, 3641–3683. DOI: <https://doi.org/10.1007/s00521-024-10694-1>
- [10] Mehta, P., Yildiz, B.S., Sait, S.M., et al., 2022. Hunger games search algorithm for global optimization of engineering design problems. *Materials Testing*. 64(4), 524–532.
- [11] Meng, Z., Yıldız, B.S., Li, G., et al., 2023. Application of state-of-the-art multiobjective metaheuristic algorithms in reliability-based design optimization: A comparative study. *Structural and Multidisciplinary Optimization*. 66, 191. DOI: <https://doi.org/10.1007/s00158-023-03639-0>
- [12] Yıldız, B.S., Mehta, P., Panagant, N., et al., 2022. A novel chaotic Runge Kutta optimization algorithm for solving constrained engineering problems. *Journal of Computational Design and Engineering*. 9(6), 2452–2465.
- [13] Yıldız, B.S., Kumar, S., Panagant, N., et al., 2023. A novel hybrid arithmetic optimization algorithm for solving constrained optimization problems. *Knowledge-Based Systems*. 271, 110554.
- [14] Anosri, S., Panagant, N., Champasak, P., et al., 2023. A comparative study of state-of-the-art metaheuristics for solving many-objective optimization

- problems of fixed wing unmanned aerial vehicle conceptual design. *Archives of Computational Methods in Engineering*. 30, 3657–3671.
- [15] Sait, S.M., Mehta, P., Gürses, D., et al., 2023. Cheetah optimization algorithm for optimum design of heat exchangers. *Materials Testing*. 65(8), 1230–1236. DOI: <https://doi.org/10.1515/mt-2023-0015>
- [16] Gürses, D., Mehta, P., Sait, S.M., et al., 2022. African vultures optimization algorithm for optimization of shell and tube heat exchangers. *Materials Testing*. 64(8), 1234–1241.
- [17] Gürses, D., Mehta, P., Sait, S.M., et al., 2023. A multi-strategy boosted prairie dog optimization algorithm for global optimization of heat exchangers. *Materials Testing*. 65(9), 1396–1404. DOI: <https://doi.org/10.1515/mt-2023-0082>
- [18] Yildiz, B.S., Pholdee, N., Mehta, P., et al., 2023. A novel hybrid flow direction optimizer-dynamic oppositional based learning algorithm for solving complex constrained mechanical design problems, *Materials Testing*. 65(1), 134–143.
- [19] Derringer, G., Suich, R., 1980. Simultaneous optimization of several response variables. *Journal of quality technology*. 12, 214–219.
- [20] Jorge, L.R., Yolanda, B.L., Diego, T., et al., 2017. Optimization of multiple response variables using desirability function and a Bayesian predictive distribution. *Research in Computing Science*. 13, 85–95.
- [21] Zheng, M., Yu, J., 2024. *Systems Theory for Engineering Practice, Insights from Physics*. Springer: Singapore. pp. 77–110
- [22] Zheng, M., Yu, J., 2024. Robust Design and Assessment of Product and Production by Means of Probabilistic Multi-Objective Optimization. Springer: Singapore. pp. 1–120.
- [23] Fang, K.T., Liu, M.Q., Qin, H., et al., 2018. *Theory and Application of Uniform Experimental Design*. Science Press & Springer Nature: Beijing & Singapore. DOI: <https://doi.org/10.1007/978-981-13-2041-5>
- [24] Fang, K.T., Wang, Y., 1994. *Number - theoretic Method in Statistics*. Chapman & Hall: London. 104–244.
- [25] Zheng, M., Yu, J., Teng, H., et al., 2024. Application of probability – based multi – objective optimization in portfolio and engineering management problems. *Technicki Glasnik*. 18(1), 8–11.
- [26] Zheng, M., Yu, J., 2023. A novel method for solving multi-objective shortest path problem in respect of probability theory. *Technicki Glasnik*. 17(4), 497–500.
- [27] Ofodu, J.C., Abifarin, J.K., 2022. Employment of probability-based multi-response optimization in high voltage thermofluids. *Military Technical Courier*. 70(2), 393–408.
- [28] Trung, D.D., Diep, M.T., Duc, D.V., et al., 2024. Application of probability theory in machine selection. *Applied Engineering Letters*. 9(4), 203–214.
- [29] Esangbedo, M.O., Abifarin, J.K., 2023. Determination and managerial implications of machine conditions for high-grade industrial polycaprolactam (nylon 6). *Scientific Reports*. 13, 10779.